



Corrigendum-I

Open E Tender No: CON/NCR/TECH/Power Pack/2017, dated 08/11/2017.

Name of the Tender: Supply, Installation, Testing and Commissioning of 05 Nos of Reefer Power Pack on Turnkey basis at ICD/Dadri, Uttar Pradesh.

Sl. No	Clause No.	Description	Clarification sought by perspective bidder	Clarification/ Amendment by CONCOR
1.	2A of section-IV	<p>DIESEL GENERATOR SET (Two sets in One Power Pack)</p> <p>An engine of Cummins/Caterpillar/Volvo/Kirloskar make, suitable for 250KVA GENSET, Turbocharged After cooled, Water cooled, electric starting, 1500 RPM, four strokes, multi-cylinder diesel engine conforming to BIS standards with 10% overloading for 01 hour in any 12 hours of continuous operation in standard operating conditions in our country. The engine should be able to take 100% load without de-ration up to 50° Centigrade. The DG Set should comply with the latest CPCB norms.</p>	<p>Please includes Greaves Cotton make DG set in list of makes</p>	<p>No, it cannot include at this stage please refer clause 2 (A) of Section IV of Tender Document.</p>
2.	D of Section-IV	<p>Supply of new/good condition of 20 ft high cube GP container for each power pack will be in the scope of contractor.</p>	<p>Which type of high cube container is to be supplied</p>	<p>20 ft High Cube end open steel Dry Freight ISO container</p>
3	F (xvii) of Section-IV	<p>Provision of air conditioner 1.5 ton (industrial Type) : The contractor is required to install</p>	<p>Please confirm the specification</p>	<p>Minimum 1.5 Ton Industrial Type air-conditioner of</p>

		suitable Air-conditioner of minimum 1.5 Ton capacity, in the operator cabin to maintain the temperature of comfort level. The Air-conditioner should with stand with jerk & vibrations.	/make of Air conditioner	reputed make will be acceptable. Air conditioner should sustain vibration level during enroute on BLC wagon.
4	F (xviii) of Section-IV	Provision of Fire Extinguishers (2 Nos) : The contractor will be supply and fix 2 nos of pressure (ABC) type 5 kg/cm ² Fire extinguishers in the Cabin area to suit at site.	Please confirm make/specification of fire extinguishers?	CONCOR will accept only ISI mark ABC Type 5 kg/cm ² fire extinguishers.
5	Clause 21 of Section IV	Clause no.21 of section IV point no 1 to 10 of tender document	Please confirm testing & inspection procedures	May please refer Clause 21 of Section IV of tender document
6	4.0-1 of section-1	Earnest Money for amount of Rs. 5,00,000/- (Rupees. Five Lakhs Only) through e-payment (NEFT/RTGS) and the receipt of the same should be scanned and uploaded in the e-tendering website www.tenderwizard.com/CCIL at the time of online tender submission.	Please confirm if we can to be submit bank guarantee in lieu of EMD	EMD cannot be submitted in the form of BG. It should be paid through e-Payment (NEFT/RTGS)

Note: All other Terms & Conditions of the tender documents will remain unchanged.