



Corrigendum-2

Open E- tender No. CON/NCR/TECH/Power Pack/2017 dated 08/11/2017

Name of the Tender: Supply, Installation, Testing and Commissioning of 05 Nos of Reefer Power Pack on Turnkey basis at ICD/Dadri

Sl. No.	Clause No.	Clarification sought by the perspective bidder	Clarification/Amendment by CONCOR
1		The tender does not have any mention of CPCB compliance requirement for the DG Sets sought in containers. We would like to high light that as per CPCB norms engine and DG Set manufacturers and suppliers are supposed to sell or supply any DG Set of rating of 10KVA to 990 KVA not meeting CPCB emission norms including use of certified acoustic enclosure for sound reduction.	Please refer clause 3 of section-II and clause -2A of section-IV.
2		We request you to consider Incorporating use of acoustic enclosure as mandatory requirement for the containers.	The perspective bidders are requested to visit OUR SITE AT ICD/Dadri and have a look on the Reefer power packs in 40 ft container already in working for that they can make them self-familiar with the scope of work and asses the work involved (please refer clause no. 6.5 of section-I of the tender document).
3		Remove the mandatory requirement of ISO certification for container supplier.	Clause D of section-IV is amended as: <u>Supply of New</u> 20ft High cube end open steel dry freight ISO container for each power pack will be in the scope of contractor.
4	Clause No. 13/ Page No. 24 :	You have requested for 2000 Ltr capacity Fuel Day Tank. Any statutory Approval required for the same form any Authorities like Chief Controller of Explosive Department (CCOE)/ Central Pollution Board/ electrical Approval shall be in scope of CONCOR/ Customer.	The approval required (if any) shall be in the scope of the contractor.

5	Please refer Clause No. 13/ Page No. 24	Diesel required for Site Testing shall be in the scope of Customer. Kindly confirm	Diesel required for Site Testing shall be in the scope of contractor.
6		Do you have any exemption from CPCB – II norms for the DG Sets up to 1000 KVA should be supplied with the noise suppressed up to 75 dB(A) on an average basis. IF, YES: Please give us supporting document from Ministry of Environment & Forest/ Central Pollution Control Board. IF, NO: Then we can achieve the Noise Level by operating 1 DG Set at a time (Not Both DG Sets together) Kindly confirm.	Please refer clause 3 of section-II and clause -2A of section-IV. We operate only one DG set at a time and the another one is as a 100% standby.

Note: All the other terms & conditions of the tender documents will remain unchanged.