

CORRIGENDUM - I

Tender No. CON/ICD/TKD/TECH/DRY TRANSFORMER/2018-19 (Supply of 03 nos, 11 KV/433 volt, 750 KVA,Dry Type Transformers at ICD/TKD).

In reference to the above tender following amendments has been made in Clause 2.2 Section I Qualifying criteria & , Item mentioned at sl.no.1, Section V, Bill of Quantity (BOQ)/Schedule of Price, the details of which are given below;

Existing Clause	Amendment
Clause 2.2 Section I,Qualification Criteria.	Clause 2.2 Section I,Qualification Criteria.
The bidder shall supply the Dry Transformers of reputed brand like ABB, Siemens, L&T, Crompton Greaves, GEAlsthom & Schneider.The Bidder shall be the OEM or Authorised dealer of the above brands and submit the Proof of the same.	<p>(i)The bidder shall supply 03 nos, 11 KV/433 volt, 750 KVA, Dry Type Transformers which should have been type tested at CPRI/NABL accredited laboratory. The bid shall accompanying with type test reports conducted at central power research institute/NABL accredited laboratory for the offered materials conducted within five years before the date of opening of the tender.</p> <p>(ii). If the bidder do not have valid type test report for the offered 03 nos, 11 KV/433 volt, 750 KVA, Dry Type Transformers within last 5 years but possess adequate supply experience of the tendered transformer or higher rating both in voltage/capacity, they have to furnish an undertaking to conduct the Type Test of the tendered Transformer offered by them in their own cost at CPRI/NABL Accredited laboratory and produce the said Type Test report along with the drawings duly approved by the Type Testing agency within 90 days of placement of the order.</p> <p>(iii) The Bidder shall be the OEM or Authorized dealer and submit the Proof of the same along with the bid.</p>
Item mentioned at sl.no.1, Section V, Bill of Quantity (BOQ)/Schedule of Price.	Item mentioned at sl.no.1, Section V, Bill of Quantity (BOQ)/Schedule of Price.
11KV/433 Volt,750 KVA ,Dry type, Indoor Distribution transformer, complete with all accessories.Make:CromptonGreaves/L&T/ Schneider/Siemens/ABB/GE Alsthom.	11KV/433 Volt,750 KVA ,Dry type, Indoor Distribution transformer, complete with all accessories.